

**Cisco 650-125**

**Cisco Substation Automation System and Field  
Engineer Knowledge Verification  
Version: 4.0**

**QUESTION NO: 1**

Which regulation is relevant to substation industry compliance?

- A. IEEE 1394
- B. NFPA-92
- C. IEC-61850-3
- D. IEEE802.1X

**Answer: C**

**Explanation:**

**QUESTION NO: 2**

How are features controlled on the Cisco CGR 2010?

- A. PAK license
- B. license soft key
- C. ISO image
- D. hardware key

**Answer: B**

**Explanation:**

**QUESTION NO: 3**

Which of the following models supports Power over Ethernet?

- A. All CGS models
- B. CGS-2520-24TC
- C. CGS-2520-16S-8PC
- D. None of the models supports POE

**Answer: A**

**Explanation:**

**QUESTION NO: 4**

What is the function of security event data processed in real time for incident response and threat management?

- A. Cisco Physical Access Manager Client
- B. Security Information Management
- C. Video Surveillance Operation Manager
- D. Security Event Management

**Answer: B**

**Explanation:**

#### **QUESTION NO: 5**

What does the acronym ATP stand for in regard to the Cisco Channel Partner program?

- A. Authorized Technology Provider
- B. Authorized TelePresence Partner
- C. Allowed to Purchase
- D. Advanced Technology Partner

**Answer: A**

**Explanation:**

#### **QUESTION NO: 6**

Which SFP modules are supported on CGR and CGS products?

- A. all SFP made by Cisco
- B. only rugged models made by Cisco
- C. all ruggedized models that support NERC/CIP compliance
- D. all SFP on the market

**Answer: B**

**Explanation:**

#### **QUESTION NO: 7**

What is the total support wattage on CGS-2520-16S-8PC on PoE when two power supplies are

installed?

- A. 210 W
- B. 65 W
- C. 170 W
- D. 20 W

**Answer: B**

**Explanation:**

#### **QUESTION NO: 8**

Why is the blank cover needed when there is only one power supply in use?

- A. Blank covers are required by the NERC/CIP Standards Committee.
- B. To ensure that the equipment has a uniform color appearance.
- C. The system can only support one power supply.
- D. To maintain the correct ventilation and environmental rating for the system.

**Answer: A**

**Explanation:**

#### **QUESTION NO: 9**

Which of these international companies is a Cisco competitor that produces hardened network equipment for use in electrical utility grids?

- A. Hewlett Packard
- B. Microsoft
- C. Garrettcom
- D. Nortel
- E. Apple Inc.

**Answer: A**

**Explanation:**

#### **QUESTION NO: 10**